



Greenfield Runoff for 1 in 100 year event 10 l/sec  
 3157 sqm impermeable area max discharge 3.2 l/sec  
 210 cum required for a 1 in 100 year event plus 30% for climate change

Storm Attenuation 210 cum  
 21x10x1.0m  
 ● 3.2l/sec 1 100 + 30%

Rev	Description	date
Client		
PADDLE HOMES LTD		
Project		
RESIDENTIAL DEVELOPMENT OFF WAUNSCIL AVENUE, BRACKLA		
Title		
NEW STORM SEWER OUTFALL TO TREMAINS ROAD		
Scale: 1:500		
Date: Mar 2020		
Drawing No. 2811/SERV/11		Rev.

**LAURENCE RAE ASSOCIATES LTD**  
 Consulting Engineers  
 435 Fishponds Road  
 BRISTOL  
 BS16 3AP  
 Tel: 0117 958 3786  
 Fax: 0117 958 4110